



Desso DLW Textil GmbH  
Stuttgarter Strasse 75  
DE-74321 BIETIGHEIM-BISSINGEN  
DUITSLAND

Your notice of

Your reference

our reference  
PW/8888

date  
2005-09-30

## Certification Report Nr. 05/8888

### 1. Description of the flooring:

Product group: Needlefelt broadloom - FS  
65% polyamide – 35% polypropylene  
full impregnation  
60% polypropylene – 40% polyester backing  
Total mass: 1000 g/m<sup>2</sup>  
Effective pile thickness: 2 mm

### 2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
C <sub>fl</sub>	E <sub>fl</sub>	heat flux ≥ 4,5 kW/m <sup>2</sup>

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

glued on a non-combustible substrate

**C<sub>fl</sub> - s1**

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.

The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

*Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment*

**CENTEXBEL GENT**  
Technologiepark 7  
BE-9052 Zwijnaarde (Gent)  
Tel. +32 9 220 41 51  
Fax +32 9 220 49 55  
e-mail gent@centexbel.be

**CENTEXBEL BRUSSELS**  
Montoyerstraat 24-B2  
BE-1000 Brussels  
Tel. +32 2 287 08 30  
Fax +32 2 230 68 15  
e-mail brussel@centexbel.be

**CENTEXBEL VERVIERS**  
Avenue du Parc 38  
BE-4650 Herve (Chaineux)  
Tel. +32 87 32 24 30  
Fax +32 87 34 05 18  
e-mail chaineux@centexbel.be



**Addressee**  
**Desso DLW Textil GmbH**

**our ref.**  
PW/8888

**date**  
2005-09-30

**page number**  
2

Related commercial names to this product group are:  
MARKA 738L

The obtained classification is based on the next test reports:  
TFI: 350867 of 2005-07-29

Certificate valid until 2010-07-29

A handwritten signature in black ink, appearing to read 'Wittevrongel', with a long horizontal flourish extending to the right.

Petra Wittevrongel  
certification coordinator